



Cycles of Concentration: 5

<p>Notes:</p> <p>1. All values in gpm unless otherwise noted.</p> <p>2. Dashed lines indicate that the flow is expected to be intermittent.</p> <p>3. Assumed inputs are listed on page 2.</p> <p>4. Cooling tower calculations per SPX Cooling Technologies BEST program.</p>			<p><b>WorleyParsons</b> resources &amp; energy</p> <p>EMI Florida Clean Energy Center Preliminary Water Balance- Design Condition Page 1 of 2</p> <p>DWG No: FCEC-1-SK-021-305-001    Rev: B    Date: 4/9/2008</p>

Assumed Inputs	
Plant Drains	20
Fire Protection	0
Service Water	25
Cycles of Concentration	5
EDI Rejection Rate	10%
Demin RO Rejection Rate	25%
Sludge Dewatering Recovery	60%
Clarifier Bottoms	2%
Coal Pile Runoff	0
Steam Cycle Blowdown	2.00%
Misc. Losses	1.00%

Cooling Tower Inputs:	
Wet Bulb Temperature	82 °F
Hot Side Temp	107 °F
Cold Side Temp	92 °F
Circ water flowrate (gpm)	70000 *Attachment B
RH%	92
Evaporation	943 *Attachment C
Feed Water Flowrate	8.65E+05 *Attachment B
lb/hr =	1728
Drift (gpm)	4
WW RO Permeate	90%

OVERALL BALANCE		
INS	OUTS	
972	0	0
20	0	0
5	4	4
0	4	4
2	947	947
	17	17
	2	2
	25	25
	0	0
TOTAL:	999	999
<b>Balance is Acceptable</b>		
Consumptive Usage		
0.00 MGD	*Base on 24 hours of operation	

Notes:

- 1 Plant drains are collected in the oil/water separator and pumped back in to the system at an average rate of 20 gpm.
- 2 Drift is assumed to be 0.005% Recirculation Rate.
- 3 Potable Water estimated by 50 gallons/day per person, site personnell is assumed as follows:
 

Plant Staff	31 people
Fuel/Ash	10 people
Visitors	7 people
Other	2 people
- 4 Boiler makeup is assumed to be 2% Steam Production at MCR boiler blowdown plus 1% Steam Production at MCR Misc. Steam Losses. Misc, Steam cycle losses include Sampling losses, Air evacuation losses, Misc. Seal Leakage, Misc. Leaks and Closed cycle cooling makeup.
- 5 Multimedia filter backwash assumed to require 6485 gallons approximately 1 time per week.
- 6 Demineralized Water System Water Recovery is as follows:
 

1st Pass RO System - 75% Recovery
2nd Pass RO System Recovery 90% Recovery
EDI System 95% Water Recovery
- 7 Water required for ash wetting is the maximum of the 10% to 30% acceptable range.
- 8 Storm water runoff is collected in the storm water basin. The pumps out of this basin are designed to empty the pond in 10 days.
- 9 Circ water flowrate is per heat balance.

<b>WorleyParsons</b> resources & energy		
EMI		
Florida Clean Energy Center		
Preliminary Water Balance- Design Condition		
Page 2 of 2		
DWG No: FCEC-1-SK-021-305-001	Rev B	Date: 4/9/2008