

## **Corrective Measures to Address Deficiencies Noted in the Coal Combustion Residuals Units Annual Inspection Report**

**(Annual inspection covering the period from December 6, 2023 – December 3,  
2024)**

As promulgated in Title 40 of the Code of Federal Regulations, Part 257.107(g)(6), Gainesville Regional Utilities (GRU) is required to post documentation detailing the corrective measures taken to remedy the deficiencies ([257.84\(b\)\(5\)](#)) noted in annual inspections on a publicly accessible internet site. Table 1 summarizes the efforts taken by GRU to address each of the deficiencies noted in the 2024 annual inspection. As available, documents that provide additional detail on the dates and actions taken to address the deficiencies are included in an attachment; Table 1 shows the corrective measure that corresponds to the attachment. Innovative Technical Solutions (ITS) engineer inspected the northern drainage ditch on March 27, 2025, to confirm the resolution of the deficiencies noted in the 2024 annual inspection.

**Table 1. Remedies Taken to Address Deficiencies Noted in the 2024 CCR Units Annual Inspection Report**

CCR Unit	Location	Previous Condition	Remedy Action	Attach.	Date of Remedy Completion
CCR Landfill	Northern Drainage Ditch	Underdrains were observed to be submerged or partially submerged underwater.	Water from the Northern Drainage Ditch was pumped to the onsite process ponds. Underdrains were above water level.	A	March 27, 2025
CCR Landfill	Landfill	Thick vegetation observed near the top of the slopes of Cells 1-3.	Outer slopes of landfill were mowed. ITS engineer inspected the vegetation on the landfill slope on May 6, 2025 and observed that the slopes are mowed.	-	April 7, 2025

## **Attachment A. Pictures After Implementing the Remedy Action**



(a)



(b)



(c)



(d)

**Figure A1. CCR Landfill Cell 1 (a), Cell 2 (b), Cell 3 (c), and Cell 4 (d) Underdrain Outlet; 3/27/2025**