

INSPECTION AND TESTING FORM

INITIATING AND SUPERVISORY DEVICE TESTS AND INSPECTIONS

DEVICE / ZONE	LOCATION	MAKER	MODEL #	TYPE	FUNCT. TEST	VISUAL CHECK	FACTORY SETTING	MEASURED SETTING	PASS	FAIL
1-1	CONTROL ROOM	SIEMENS	HFP-11	PHOTO	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	.77-2.37%/FT		<input checked="" type="checkbox"/>	<input type="checkbox"/>
1-21	FRONT DOOR	SIEMENS	HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-10	HALL AT CONFRENCE ROOM	SIEMENS	HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-11	HALL AT NORTH EXIT		HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-12	NORTH HALL		HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-9	EAST HALL		HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-25	ELECTRIC ROOM		HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-22	KITCHEN		HFP-11	PHOTO	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-18	KITCHEN		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>	.41-1.37%/FT		<input type="checkbox"/>	<input type="checkbox"/>
1-19	KITCHEN		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-20	FRONT DOOR		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-15	NORTH HALL		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-16	EAST HALL		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-17	EAST HALL		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-26	KITCHEN		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-14	N.W. OFFICE		AD2-P	DUCT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-6	MOP CLOSET		HFPT-11	HEAT	<input type="checkbox"/>	<input type="checkbox"/>	135°		<input type="checkbox"/>	<input type="checkbox"/>
1-7	KITCHEN		HFPT-11	HEAT	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
	ELECTRIC ROOM	POTTER	VSR	FLOW	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
	ELECTRIC ROOM	VICTAULIC	705	TAMPER BFLY	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>
1-002	DCS ROOM	SIEMENS	MSM-K	PULL	<input type="checkbox"/>	<input type="checkbox"/>			<input type="checkbox"/>	<input type="checkbox"/>

