

## Smith, Justin L

---

**From:** Smith, Justin L  
**Sent:** Thursday, January 6, 2022 11:00 AM  
**To:** swpp@dep.state.fl.us  
**Cc:** Embry, Regina G; James Wally; Pradeep Jain  
**Subject:** GRU CCR Landfill Groundwater Assessment Monitoring Results Dec 2021

Per the requirements of the 40 CFR 257.95(g) and 40 CFR 257.105(h)(8), this email serves as notification that radium 226 and 228 have been detected at a statistically significant level above the groundwater protection standard at the Coal Combustion Residuals Landfill at Deerhaven Generating Station. Per the requirements of 40 CFR 257.106(h)(6) and 40 CFR 257.107(h)(6), a copy of this notification has been placed in the operating record and will be posted to GRU's publicly-accessible internet site within 30 days of placement in the operating record, respectively.

**Justin L. Smith, PE**  
Environmental Permitting and Compliance  
Gainesville Regional Utilities  
w: 352-393-1266

