

NOTICE TO CONTRACTORS – ELECTRIC METERING REQUIREMENTS

- All specifications for **electric meter centers, self-contained or transformer-rated meter sockets, CT cabinets, and metering enclosures** must be submitted to the GRU Electric Metering Department for approval **prior to any purchase or installation**.
- MEG-approved (Meter Equipment Group) equipment is preferred; however, **GRU Electric Metering retains final approval authority** for all metering equipment, regardless of manufacturer.
- Contractors are responsible for full compliance with all GRU metering standards. Refer to **GRU's Energy Delivery Service Guide, Section 3: Metering at Secondary Voltages**, @ <https://www.gru.com/Portals/0/Legacy/Pdf/StandPage/ED%20Service%20Guide.pdf> for applicable requirements.
- For questions or clarification, contact:
Pete Jones – Electric Measurement Supervisor
jonesjp@gru.com or 352-393-1592
- **Electric one-line diagrams, riser diagrams, panel schedules, and load calculations shall be submitted at the earliest project stage** for any new or modified electrical services. Failure to provide these documents promptly may result in delays or rejection of the electrical service design.